



XSICEL 2021

Transición energética en la 4ta revolución industrial



Universidad
Tecnológica
de Pereira



UNIVERSIDAD
NACIONAL
DE COLOMBIA

Impact of the integration of energy-saving strategies on the demand profile of residential buildings in a tropical climate: a case study

Authors:

MSc. J. Cárdenas-Rangel

Dr. G. Osma-Pinto

Dr. J. Jaramillo-Ibarra

Institutions:

Universidad Industrial de Santander

Contents

I. Introduction

II. Proposed methodology


III. Results

IV. Conclusions

V. Questions

I. Introduction

Building impacts



I. Introduction

Building's energy consumption




Figure 1. Global share of buildings and construction final energy and emissions 2019.
Source: 2020 Global Status Report for Buildings and Construction.

The buildings and construction sector is a key player in the fight against the climate crisis. This sector represents 35% of final energy use and 38% of emissions.

I. Introduction

Building's energy consumption in Colombia




Figure 2. Distribution of the final electricity consumption of the SIN for 2020.
Source: Adapted from BECO – UPME 2021.


I. Introduction

Reduction of energy consumption in buildings

Passive measures



Hybrid measures



Renewable energy sources



Active measures



The massive integration of energy saving strategies in buildings is being promoted locally through energy standards and / or regulations.


I. Introduction

RES. 0549 of 2015



Minimum energy saving requirements

Energía	Porcentaje mínimo de ahorro			
	Frio	Templado	Cálido seco	Cálido húmedo
Con respecto a la línea base				
Hoteles	20	35	25	45
Hospitales	35	25	35	30
Oficinas	30	30	40	30
Centros comerciales	25	40	35	30
Educativos	45	40	40	35
Vivienda no VIS	25	25	25	45
Vivienda VIS	20	15	20	20
Vivienda VIP	15	15	20	15



Climate zoning




Savings strategies recommendation

I. Introduction

RES. 0549 of 2015

CÁLIDO SECO	Hotel	Oficina	Centro comercial	Hospital	Educativo	Vivienda no VIS	Vivienda VIS/VIP
Relación ventana pared	x	x	x	x	x	x	x
Protección solar	x	x	x	x	x	x	
Ventilación natural	x	x	x	x	x	x	
Luz día y control de luz día	x	x		x	x		
Iluminación de energía eficiente	x	x	x	x	x		
Coefficiente de Desempeño (COP)	x	x	x	x			x
Recuperación de calor del aire de retorno				x			
Varidores de velocidad - torres de enfriamiento	x	x					
Sensores de monitoreo de carbono para parqueaderos (CO)	x	x	x				
Varidores de velocidad - bombas	x	x	x				
Controles: sensores de ocupación	x	x			x		
Control de iluminación exterior		x			x		
Sub-medidores de electricidad		x	x				
Corrección de Factor de Potencia	x	x	x	x	x	x	x
Agua caliente solar	x			x		x	
Accesorios de conservación de agua	x	x	x	x	x	x	x
Tratamiento de aguas residuales y reciclaje de agua							
Recolección de aguas lluvia y reutilización							

What is the impact of integrating these measures?



1 Baseline indicator

kWh/m ² -año	Frio	Templado	Cálido seco	Cálido húmedo
Hoteles	96,1	151,3	132,5	217,8
Hospitales	249,6	108,3	344,1	344,1
Oficinas	81,2	132,3	318,2	221,3
Centros comerciales	403,8	187,8	187,8	231,5
Educativos	40,0	44,0	72,0	29,8
Vivienda no VIS	46,5	48,3	36,9	50,2
Vivienda VIS	44,6	44,0	34,6	49,3
Vivienda VIP	48,1	53,3	44,9	50,6


2 Indicator calculated by simulation




	Total Energy [kWh]	Energy Per Total Building Area [kWh/m ²]	Energy Per Conditioned Building Area [kWh/m ²]
Total Site Energy	130421.52	30.50	752.21
Net Site Energy	130421.52	30.50	752.21
Total Source Energy	413044.95	96.61	2382.24
Net Source Energy	413044.95	96.61	2382.24

I. Introduction

Findings from the literature review



II. Proposed methodology



II. Proposed methodology


Description of the building under study



Characteristic	Value / Details
Construction system	Industrialized with a structure of plates and concrete walls.
Approximate WWR	19
Exterior walls configuration	Wall in concrete, putty, and paint inside, plastic stucco outside. Overall thickness: 13 cm
Exterior walls U value [$\text{W/m}^2\cdot\text{K}$]	3.25
Roof configuration	Solid concrete plate, stucco, and lower face paint. Mortar, asphalt layer, and reflective paint on the upper face. Overall thickness: 16 cm
Cover U value [$\text{W/m}^2\cdot\text{K}$]	2.76
Lighting power density - LPD [W/m^2]	2.22
Power Density of plug-in charges [W/m^2]	31.49
Average power consumption [kWh/m^2]	130
Air conditioning system	The main room of some of the apartment typologies (9000 BTU)
Elevators	1 x 7.5 HP
Apartment area [m^2]	4145.0
General services área [m^2]	456.6


II. Proposed methodology

Energy modeling



II. Proposed methodology

Evaluation of the impact of strategies



III. Results

Annual energy consumption




Fig. 3. Annual energy consumption of the different simulation scenarios. Source: Authors.

III. Results

Real Scenario




Fig. 4. The hourly curve of the energy demanded the real scenario. Source: Authors.

III. Results

Comparison of the demand curve for scenarios




Fig. 5. Hourly energy consumption curves for the different simulation scenarios. Source: Authors.

III. Results

Comparison of the demand curve for scenarios




Fig. 6. Hourly curves of energy consumption for the use of air conditioning in the different simulation scenarios considered.
Source: Authors.

III. Results

Comparison of the demand curve for scenarios




Fig. 7. Comparison of hourly consumption concerning the reference scenario. Source: Authors.

III. Results

Comparison of the demand curve for scenarios




Fig. 8. Transformer chargeability analysis. Source: Authors.

III. Results

Comparison of energy use intensity indicators

Scen.	kWh/m ² /year	Baseline kWh/m ² /year		Savings Hot-Dry [%]	Savings Tempered [%]
		Hot-Dry	Tempered		
0	30.50	36.9	48.3	17%	37%
1	38.06			-3%	21%
2	30.33			18%	37%
3	26.60			28%	45%
4	30.52			17%	37%

IV. Conclusions

- The main determinants of energy consumption in the scenarios analyzed are plug-in equipment. These represent around 75% of total consumption.
- The presence of efficient elevators and LED lighting in the real configuration (Scenario 0) produces a saving percentage of 17%. concerning the baseline of Resolution 0549. However, under a temperate climate, the savings are close to 37%.
- Most of the scenarios that include strategies do not present significant changes in energy demand. Compliance with local regulations requires the integration of additional strategies. The opposite case occurs with the natural ventilation scenario. This is the only one that allows minimum savings to be achieved under hot-dry weather conditions.

IV. Conclusions

- The results allow appreciating that energy-saving strategies can influence the chargeability of the transformer. For this study, the integration of natural ventilation reduces the energy demand and makes that chargeability is near 25% most of the time.

IV. QUESTIONS

